Report No.: Test Time: 2026-10-06 16:13

Luminaire Property


Luminaire Manufacturer:
Luminaire Description: LITE 45-250MA-50D
Lamp Description: BLX V6HD F90 3000K
Luminous Length (mm): -42
Luminous Width (mm): -42
Voltage: 230.7 V
Current: 0.082 A
Power: 10.00 W
Power Factor: 0.520

Photometric Results

CIE Class: Direct
Total Rated Lamp Lumens: 938.4 lm
Measurement Flux: 938.4 lm
Efficiency: 100%
Downward Ratio: 100%
Upward Ratio: 0%
Horizontal Diffuse Angle(50%): H52.8
Vertical Diffuse Angle(50%): V52.8
Luminaire Efficacy Rating (LER): 93.88
Central Intensity: 1253.59 cd
Max. Intensity: 1325.67 cd
Pos of Max. Intensity: H0 V10
S/MH(C0/C180): 0.87
S/MH(C90/C270): 0.87


Picture Of Luminaire


Luminous Intensity Distribution Curve



C Plane (°):0.0-180.0: 180.0
Gamma Plane (°):0.0-90.0:1.0
Test Lab:
Test Device: CHL-6E
Test Type: TYPE C
Distance: 3.218 m
Temperature:
Humidity:
Operator:
Inspector:

Luminous Intensity Distribution Curve






C Plane (°):0.0-180.0: 180.0
Test Lab:
Test Type: TYPE C
Temperature:
Operator:

Gamma Plane (°):0.0-90.0:1.0
Test Device: CHL-6E
Distance: 3.218 m
Humidity:
Inspector:


Luminous Intensity Distribution Curve(cd/klm)



C Plane (°):0.0-180.0: 180.0
Test Lab:
Test Type: TYPE C
Temperature:
Operator:

Gamma Plane (°):0.0-90.0:1.0
Test Device: CHL-6E
Distance: 3.218 m
Humidity:
Inspector:

Isocandela (rectangle)




Imax (100%): 1326 cd

(10%): 133 cd
(16%): 212 cd
(25%): 331 cd
(40%): 530 cd
(63%): 835 cd
(100%): 1326 cd

C Plane (°):0.0-180.0: 180.0
Gamma Plane (°):0.0-90.0:1.0
Test Lab:
Test Device: CHL-6E
Test Type: TYPE C
Distance: 3.218 m
Temperature:
Humidity:
Operator:
Inspector:

IsoLux Plot




Mounting Height: 10.0m Max Lux(100%): 12.8 lx

(1%): 0.1 lx
(2%): 0.3 lx
(5%): 0.6 lx
(10%): 1.3 lx
(20%): 2.6 lx
(50%): 6.4 lx
(100%): 12.8 lx

C Plane (°):0.0-180.0: 180.0
Gamma Plane (°):0.0-90.0:1.0
Test Lab:
Test Device: CHL-6E
Test Type: TYPE C
Distance: 3.218 m
Temperature:
Humidity:
Operator:
Inspector:

Illuminance at a Distance




Dist(m)	Enadir(lx)	Dh/Dv_B(m)	S_B(sq.m)	Eav_B(lx)
0.5	5014.36	0.49/0.50	0.2	2144.54
1.0	1253.59	0.98/1.00	0.8	536.13
1.5	557.15	1.47/1.49	1.7	238.28
2.0	313.40	1.96/1.99	3.1	134.03
2.5	200.57	2.45/2.49	4.8	85.78
3.0	139.29	2.94/2.99	7.0	59.57
4.0	78.35	3.92/3.98	12.4	33.51
5.0	50.14	4.89/4.98	19.3	21.45
15.0	5.57	14.68/14.94	173.9	2.38
20.0	3.13	19.58/19.92	309.2	1.34

Beam Angle(B): H52.2 V52.9 Field Angle(F): H73.6 V73.9

C Plane (°):0.0-180.0: 180.0
Test Lab:
Test Type: TYPE C
Temperature:
Operator:

Gamma Plane (°):0.0-90.0:1.0
Test Device: CHL-6E
Distance: 3.218 m
Humidity:
Inspector:

Vertical IsoLux Plot



Lowest(m): 1.0m Highest(m): 11.0m Max Lux: 1270.4 lx

(1%): 12.7 lx
(2%): 25.4 lx
(5%): 63.5 lx
(10%): 127.0 lx
(20%): 254.1 lx
(50%): 635.2 lx
(100%):1270.4 lx

C Plane (°):0.0-180.0: 180.0
Gamma Plane (°):0.0-90.0:1.0
Test Lab:
Test Device: CHL-6E
Test Type: TYPE C
Distance: 3.218 m
Temperature:
Humidity:
Operator:
Inspector:

Area Flux Table

Unit: lm


Horizontal plane	Vertical plane																									
	Flux(E)	Flux(T)	90	80	70	60	50	40	30	20	10	0	-10	-20	-30	-40	-50	-60	-70	-80	-90	Flux(T)	Flux(E)
-90	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
-80	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
-70	0.0	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
-60	0.0	1.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0		
-50	0.0	3.1	0.0	0.0	0.0	0.0	0.0	0.2	0.3	0.4	0.5	0.5	0.5	0.4	0.3	0.2	0.1	0.0	0.0	0.0	0.0		
-40	13.1	20.2	0.0	0.0	0.0	0.0	0.1	0.4	1.1	3.2	5.0	5.0	5.0	3.2	1.1	0.4	0.2	0.1	0.0	0.0	0.0		
-30	75.5	80.1	0.0	0.0	0.1	0.2	0.4	1.2	5.9	13.5	18.8	18.8	13.5	5.9	1.2	0.4	0.2	0.1	0.0	0.0	0.0		
-20	154.3	158.4	0.0	0.0	0.1	0.2	0.5	3.6	14.4	27.2	33.2	33.2	27.2	14.4	3.6	0.5	0.2	0.1	0.0	0.0	0.0		
-10	197.5	201.4	0.0	0.0	0.1	0.3	0.7	5.8	20.9	35.0	37.9	37.9	35.0	20.9	5.8	0.7	0.3	0.1	0.0	0.0	0.0		
0	201.1	205.0	0.0	0.0	0.1	0.3	0.7	5.8	21.0	35.6	39.1	39.1	35.6	21.0	5.8	0.7	0.3	0.1	0.0	0.0	0.0		
10	159.9	164.1	0.0	0.0	0.1	0.2	0.5	3.5	14.5	28.1	35.3	35.3	28.1	14.5	3.5	0.5	0.2	0.1	0.0	0.0	0.0		
20	76.4	81.2	0.0	0.0	0.1	0.2	0.4	1.2	5.7	13.7	19.5	19.5	13.7	5.7	1.2	0.4	0.2	0.1	0.0	0.0	0.0		
30	11.4	18.8	0.0	0.0	0.0	0.1	0.2	0.4	1.1	2.9	4.7	4.7	2.9	1.1	0.4	0.2	0.1	0.0	0.0	0.0	0.0		
40	0.0	3.0	0.0	0.0	0.0	0.0	0.1	0.2	0.3	0.4	0.5	0.5	0.4	0.3	0.2	0.1	0.1	0.0	0.0	0.0	0.0		
50	0.0	1.1	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0		
60	0.0	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
70	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
80	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
90		938	0.0	0.0	0.1	0.6	1.6	3.9	22.4	85.4	160.2	194.9	194.9	160.2	85.4	22.4	3.9	1.6	0.6	0.1	0.0	938	
	889		0.0	0.0	0.0	0.0	0.0	14.4	81.2	157.0	192.0	192.0	157.0	81.2	14.4	0.0	0.0	0.0	0.0	0.0	0.0		889

C Plane (°):0.0-180.0: 180.0
Test Lab:
Test Type: TYPE C
Temperature:
Operator:

Gamma Plane (°):0.0-90.0:1.0
Test Device: CHL-6E
Distance: 3.218 m
Humidity:
Inspector:

The Average Illuminance Effective Figure

Flux Out: 674.70lm



Height Avg./Nadir. E Beam Angle:52.2° Diameter / Area

C Plane (°):0.0-180.0: 180.0
Test Lab:
Test Type: TYPE C
Temperature:
Operator:

Gamma Plane (°):0.0-90.0:1.0
Test Device: CHL-6E
Distance: 3.218 m
Humidity:
Inspector:

UGR Table


Reflectance:										
Ceiling (cavity)	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions	Viewed crosswise					Viewed endwise				
X=2H Y=2H	19.4	20.2	19.7	20.4	20.6	19.5	20.3	19.8	20.5	20.7
3H	19.3	20.0	19.6	20.2	20.5	19.4	20.1	19.7	20.4	20.6
4H	19.2	19.9	19.5	20.1	20.4	19.4	20.0	19.7	20.3	20.5
6H	19.1	19.8	19.5	20.1	20.3	19.3	19.9	19.6	20.2	20.5
8H	19.1	19.7	19.5	20.0	20.3	19.2	19.8	19.6	20.1	20.4
12H	19.1	19.6	19.4	19.9	20.3	19.2	19.8	19.6	20.1	20.4
X=4H Y=2H	19.2	19.9	19.5	20.1	20.4	19.4	20.0	19.7	20.3	20.5
3H	19.1	19.7	19.5	20.0	20.3	19.2	19.8	19.6	20.1	20.4
4H	19.0	19.5	19.4	19.9	20.2	19.2	19.7	19.5	20.0	20.4
6H	18.9	19.4	19.4	19.8	20.1	19.1	19.5	19.5	19.9	20.3
8H	18.9	19.3	19.3	19.7	20.1	19.0	19.4	19.5	19.8	20.2
12H	18.9	19.2	19.3	19.6	20.1	19.0	19.3	19.4	19.8	20.2
X=8H Y=4H	18.9	19.3	19.3	19.7	20.1	19.0	19.4	19.5	19.8	20.2
6H	18.8	19.1	19.3	19.6	20.0	18.9	19.3	19.4	19.7	20.1
8H	18.8	19.1	19.2	19.5	20.0	18.9	19.2	19.4	19.6	20.1
12H	18.7	19.0	19.2	19.4	19.9	18.8	19.1	19.3	19.6	20.1
X=12H Y=4H	18.9	19.2	19.3	19.6	20.1	19.0	19.4	19.4	19.8	20.2
6H	18.8	19.1	19.2	19.5	20.0	18.9	19.2	19.4	19.6	20.1
8H	18.7	19.0	19.2	19.4	19.9	18.8	19.1	19.3	19.6	20.1
Variations with the observer position at spacings:										
S=1.0H	+5.9/-8.8					+5.9/-9.1				
S=1.5H	+8.7/-11.2					+8.7/-11.5				
S=2.0H	+10.7/-13.2					+10.7/-13.6				

Calculate in accordance with CIE Pub.117. The table is revised with 938lm (8log(F/F0) = -0.2).

C Plane (°):0.0-180.0: 180.0
Test Lab:
Test Type: TYPE C
Temperature:
Operator:

Gamma Plane (°):0.0-90.0:1.0
Test Device: CHL-6E
Distance: 3.218 m
Humidity:
Inspector:

FLUX DISTRIBUTION TABLE BASED ON THE IESNA LUMINAIRE CLASSIFICATION SYSTEM



ZONE	LUMENS	% LAMP LUMENS
FORWARD LIGHT	474	50.5
FL (0°-30°)	398	42.4
FM (30°-60°)	74	7.9
FH (60°-80°)	2	0.2
FVH (80°-90°)	0	0.0
BACK LIGHT	465	49.5
BL (0°-30°)	386	41.2
BM (30°-60°)	77	8.2
BH (60°-80°)	2	0.2
BVH (80°-90°)	0	0.0
UP LIGHT	0	0.0
UL (90°-100°)	0	0.0
UH (100°-180°)	0	0.0
TRAPPED LIGHT	NA	NA

BUG(**B**acklight,**U**plight,**G**lare) Rating Base On TM-15-07	
Asymmetrical Luminaire Types (Type I,II,III,IV)	B1 U0 G0
Quadrilateral Symmetrical Luminaire Types (Type V,Area Light)	B1 U0 G0

C Plane (°):0.0-180.0: 180.0
Test Lab:
Test Type: TYPE C
Temperature:
Operator:

Gamma Plane (°):0.0-90.0:1.0
Test Device: CHL-6E
Distance: 3.218 m
Humidity:
Inspector:

Zonal Lumen

Gamma [°]	Imean [cd]	Zonal Flux [lm]	Sum Zonal Flux [lm]	Rel Zonal Flux [%]	Sum Rel Zonal Flux [%]
0.0-1.0	1253.8	1.2	1.2	0.13	0.13
1.0-2.0	1255.0	3.6	4.8	0.38	0.51
2.0-3.0	1257.5	6.0	10.8	0.64	1.15
3.0-4.0	1261.1	8.4	19.3	0.90	2.05
4.0-5.0	1265.2	10.9	30.1	1.16	3.21
5.0-6.0	1269.3	13.3	43.5	1.42	4.63
6.0-7.0	1273.2	15.8	59.3	1.68	6.32
7.0-8.0	1276.3	18.3	77.6	1.95	8.27
8.0-9.0	1277.7	20.7	98.3	2.21	10.47
9.0-10.0	1277.4	23.1	121.4	2.46	12.94
10.0-11.0	1275.1	25.5	146.9	2.72	15.65
11.0-12.0	1269.7	27.8	174.6	2.96	18.61
12.0-13.0	1260.4	29.9	204.5	3.19	21.80
13.0-14.0	1246.4	31.9	236.5	3.40	25.20
14.0-15.0	1227.5	33.7	270.2	3.59	28.79
15.0-16.0	1203.5	35.3	305.4	3.76	32.55
16.0-17.0	1173.5	36.5	342.0	3.90	36.44
17.0-18.0	1137.5	37.5	379.5	4.00	40.44
18.0-19.0	1095.1	38.1	417.6	4.06	44.50
19.0-20.0	1046.6	38.3	455.9	4.08	48.59
20.0-21.0	993.9	38.2	494.1	4.07	52.65
21.0-22.0	938.1	37.7	531.8	4.02	56.67
22.0-23.0	880.0	36.9	568.7	3.94	60.61
23.0-24.0	820.8	35.9	604.6	3.82	64.43
24.0-25.0	760.7	34.6	639.2	3.69	68.12
25.0-26.0	699.4	33.0	672.2	3.52	71.64
26.0-27.0	637.1	31.2	703.4	3.32	74.96
27.0-28.0	574.8	29.1	732.5	3.10	78.06
28.0-29.0	513.8	26.9	759.4	2.87	80.93
29.0-30.0	455.3	24.6	784.0	2.62	83.55
30.0-31.0	399.2	22.2	806.2	2.37	85.91
31.0-32.0	345.6	19.8	826.0	2.11	88.03
32.0-33.0	294.4	17.3	843.3	1.85	89.87
33.0-34.0	247.1	15.0	858.3	1.59	91.47
34.0-35.0	206.7	12.8	871.1	1.37	92.84
35.0-36.0	172.5	11.0	882.1	1.17	94.01

C Plane (°):0.0-180.0: 180.0
Test Lab:
Test Type: TYPE C
Temperature:
Operator:

Gamma Plane (°):0.0-90.0:1.0
Test Device: CHL-6E
Distance: 3.218 m
Humidity:
Inspector:

Zonal Lumen (Continue 1)

Gamma [°]	Imean [cd]	Zonal Flux [lm]	Sum Zonal Flux [lm]	Rel Zonal Flux [%]	Sum Rel Zonal Flux [%]
36.0-37.0	141.4	9.2	891.3	0.98	94.99
37.0-38.0	112.3	7.5	898.8	0.80	95.79
38.0-39.0	86.6	5.9	904.7	0.63	96.42
39.0-40.0	66.2	4.6	909.4	0.49	96.91
40.0-41.0	50.6	3.6	913.0	0.38	97.30
41.0-42.0	38.5	2.8	915.8	0.30	97.59
42.0-43.0	29.2	2.2	917.9	0.23	97.82
43.0-44.0	23.1	1.7	919.7	0.19	98.01
44.0-45.0	19.8	1.5	921.2	0.16	98.17
45.0-46.0	18.0	1.4	922.6	0.15	98.32
46.0-47.0	16.7	1.3	923.9	0.14	98.46
47.0-48.0	15.5	1.3	925.2	0.13	98.60
48.0-49.0	14.3	1.2	926.4	0.13	98.72
49.0-50.0	13.1	1.1	927.5	0.12	98.84
50.0-51.0	12.1	1.0	928.5	0.11	98.95
51.0-52.0	11.4	1.0	929.5	0.10	99.05
52.0-53.0	10.6	0.9	930.4	0.10	99.15
53.0-54.0	9.7	0.9	931.2	0.09	99.24
54.0-55.0	8.8	0.8	932.0	0.08	99.32
55.0-56.0	7.8	0.7	932.7	0.08	99.40
56.0-57.0	7.0	0.6	933.4	0.07	99.47
57.0-58.0	6.3	0.6	933.9	0.06	99.53
58.0-59.0	5.6	0.5	934.5	0.06	99.59
59.0-60.0	4.9	0.5	934.9	0.05	99.64
60.0-61.0	4.4	0.4	935.4	0.04	99.68
61.0-62.0	4.0	0.4	935.7	0.04	99.72
62.0-63.0	3.5	0.3	936.1	0.04	99.76
63.0-64.0	3.0	0.3	936.4	0.03	99.79
64.0-65.0	2.7	0.3	936.6	0.03	99.82
65.0-66.0	2.5	0.3	936.9	0.03	99.85
66.0-67.0	2.2	0.2	937.1	0.02	99.87
67.0-68.0	2.0	0.2	937.3	0.02	99.89
68.0-69.0	1.7	0.2	937.5	0.02	99.91
69.0-70.0	1.4	0.1	937.6	0.02	99.92
70.0-71.0	1.3	0.1	937.8	0.01	99.94
71.0-72.0	1.1	0.1	937.9	0.01	99.95

C Plane (°):0.0-180.0: 180.0
Test Lab:
Test Type: TYPE C
Temperature:
Operator:

Gamma Plane (°):0.0-90.0:1.0
Test Device: CHL-6E
Distance: 3.218 m
Humidity:
Inspector:

Zonal Lumen (Continue 2)

Gamma [°]	Imean [cd]	Zonal Flux [lm]	Sum Zonal Flux [lm]	Rel Zonal Flux [%]	Sum Rel Zonal Flux [%]
72.0-73.0	0.9	0.1	938.0	0.01	99.96
73.0-74.0	0.8	0.1	938.1	0.01	99.97
74.0-75.0	0.7	0.1	938.1	0.01	99.98
75.0-76.0	0.7	0.1	938.2	0.01	99.99
76.0-77.0	0.5	0.1	938.3	0.01	99.99
77.0-78.0	0.3	0.0	938.3	0.00	99.99
78.0-79.0	0.2	0.0	938.3	0.00	100.00
79.0-80.0	0.2	0.0	938.3	0.00	100.00
80.0-81.0	0.1	0.0	938.3	0.00	100.00
81.0-82.0	0.0	0.0	938.3	0.00	100.00
82.0-83.0	0.0	0.0	938.3	0.00	100.00
83.0-84.0	0.0	0.0	938.3	0.00	100.00
84.0-85.0	0.0	0.0	938.3	0.00	100.00
85.0-86.0	0.0	0.0	938.3	0.00	100.00
86.0-87.0	0.0	0.0	938.3	0.00	100.00
87.0-88.0	0.0	0.0	938.3	0.00	100.00
88.0-89.0	0.0	0.0	938.3	0.00	100.00
89.0-90.0	0.0	0.0	938.3	0.00	100.00

C Plane (°):0.0-180.0: 180.0
Test Lab:
Test Type: TYPE C
Temperature:
Operator:

Gamma Plane (°):0.0-90.0:1.0
Test Device: CHL-6E
Distance: 3.218 m
Humidity:
Inspector:

Candlepower Table

Unit: cd

G\C	C0.0	C180.0								
G0.0	1253.6	1253.6								
G1.0	1259.4	1248.4								
G2.0	1267.5	1244.7								
G3.0	1275.7	1242.3								
G4.0	1285.8	1240.4								
G5.0	1295.5	1239.0								
G6.0	1304.7	1238.0								
G7.0	1313.8	1236.4								
G8.0	1320.3	1234.7								
G9.0	1324.1	1231.4								
G10.0	1325.7	1228.2								
G11.0	1323.3	1223.2								
G12.0	1316.7	1215.7								
G13.0	1304.9	1204.3								
G14.0	1287.7	1188.6								
G15.0	1265.3	1168.6								
G16.0	1236.1	1143.9								
G17.0	1199.9	1114.1								
G18.0	1157.8	1078.4								
G19.0	1108.8	1035.3								
G20.0	1054.3	987.9								
G21.0	996.0	937.2								
G22.0	935.8	883.4								
G23.0	873.0	827.8								
G24.0	810.5	771.9								
G25.0	747.2	713.4								
G26.0	681.8	655.2								
G27.0	615.7	595.8								
G28.0	550.2	537.5								
G29.0	486.3	481.4								
G30.0	425.8	427.6								
G31.0	368.3	375.3								
G32.0	313.0	325.9								
G33.0	260.3	278.5								
G34.0	215.4	234.2								
G35.0	178.8	198.2								
G36.0	146.9	165.9								

C Plane (°):0.0-180.0: 180.0
Test Lab:
Test Type: TYPE C
Temperature:
Operator:

Gamma Plane (°):0.0-90.0:1.0
Test Device: CHL-6E
Distance: 3.218 m
Humidity:
Inspector:

Candlepower Table (Continue 1)

Unit: cd

G\C	C0.0	C180.0								
G37.0	118.1	134.9								
G38.0	91.1	105.2								
G39.0	69.5	80.7								
G40.0	53.0	61.6								
G41.0	41.2	46.7								
G42.0	30.9	35.2								
G43.0	24.2	26.4								
G44.0	20.6	21.3								
G45.0	18.5	18.9								
G46.0	17.2	17.5								
G47.0	16.1	16.0								
G48.0	14.9	14.9								
G49.0	13.7	13.7								
G50.0	12.5	12.5								
G51.0	11.7	11.8								
G52.0	11.0	11.0								
G53.0	10.3	9.9								
G54.0	9.4	9.1								
G55.0	8.4	8.1								
G56.0	7.6	7.2								
G57.0	6.9	6.5								
G58.0	6.2	5.8								
G59.0	5.3	5.2								
G60.0	4.8	4.5								
G61.0	4.1	4.1								
G62.0	3.8	3.8								
G63.0	3.4	2.9								
G64.0	2.9	2.8								
G65.0	2.8	2.6								
G66.0	2.6	2.2								
G67.0	2.2	1.9								
G68.0	2.1	1.7								
G69.0	1.5	1.4								
G70.0	1.4	1.4								
G71.0	1.2	1.2								
G72.0	1.2	0.9								
G73.0	0.9	0.9								

C Plane (°):0.0-180.0: 180.0
Test Lab:
Test Type: TYPE C
Temperature:
Operator:

Gamma Plane (°):0.0-90.0:1.0
Test Device: CHL-6E
Distance: 3.218 m
Humidity:
Inspector:

Candlepower Table (Continue 2)

Unit: cd

G\C	C0.0	C180.0								
G74.0	0.9	0.5								
G75.0	0.9	0.5								
G76.0	0.7	0.7								
G77.0	0.5	0.2								
G78.0	0.2	0.2								
G79.0	0.2	0.3								
G80.0	0.2	0.0								
G81.0	0.2	0.0								
G82.0	0.0	0.0								
G83.0	0.0	0.0								
G84.0	0.0	0.0								
G85.0	0.0	0.0								
G86.0	0.0	0.0								
G87.0	0.0	0.0								
G88.0	0.0	0.0								
G89.0	0.0	0.0								
G90.0	0.0	0.0								

C Plane (°):0.0-180.0: 180.0
Test Lab:
Test Type: TYPE C
Temperature:
Operator:

Gamma Plane (°):0.0-90.0:1.0
Test Device: CHL-6E
Distance: 3.218 m
Humidity:
Inspector: