中山雅大光电有限公司
www.artdon.cn
0760-22211886
0760-22211890

Report No.: Test Time: 2026-09-11 17:27

Luminaire Property


Luminaire Manufacturer:
Luminaire Description: LITE-55
Luminous Length (mm): -51
Luminous Width (mm): -51
Voltage: 225.5 V
Current: 0.070 A
Power: 15.20 W
Power Factor: 0.963

Photometric Results

CIE Class: Direct
Total Rated Lamp Lumens: 1296.7 lm
Measurement Flux: 1296.7 lm
Efficiency: 100%
Downward Ratio: 100%
Upward Ratio: 0%
Horizontal Diffuse Angle(50%): H49.1
Vertical Diffuse Angle(50%): V49.1
Luminaire Efficacy Rating (LER): 85.36
Central Intensity: 1989.8 cd
Max. Intensity: 1996.71 cd
Pos of Max. Intensity: H0 V3
S/MH(C0/C180): 0.79
S/MH(C90/C270): 0.79


Picture Of Luminaire


Luminous Intensity Distribution Curve



C Plane (°):0.0-180.0: 180.0
Gamma Plane (°):0.0-90.0:1.0
Test Lab:
Test Device: CHL-6E
Test Type: TYPE C
Distance: 3.010 m
Temperature:
Humidity:
Operator:
Inspector:

Luminous Intensity Distribution Curve






C Plane (°):0.0-180.0: 180.0
Test Lab:
Test Type: TYPE C
Temperature:
Operator:

Gamma Plane (°):0.0-90.0:1.0
Test Device: CHL-6E
Distance: 3.010 m
Humidity:
Inspector:


Luminous Intensity Distribution Curve(cd/klm)



C Plane (°):0.0-180.0: 180.0
Test Lab:
Test Type: TYPE C
Temperature:
Operator:

Gamma Plane (°):0.0-90.0:1.0
Test Device: CHL-6E
Distance: 3.010 m
Humidity:
Inspector:

Isocandela (rectangle)




Imax (100%): 1997 cd

(10%): 200 cd	(16%): 319 cd
(25%): 499 cd	(40%): 799 cd
(63%): 1258 cd	(100%): 1997 cd

C Plane (°):0.0-180.0: 180.0
Test Lab:
Test Type: TYPE C
Temperature:
Operator:

Gamma Plane (°):0.0-90.0:1.0
Test Device: CHL-6E
Distance: 3.010 m
Humidity:
Inspector:

IsoLux Plot




Mounting Height: 10.0m Max Lux(100%): 19.9 lx

(1%): 0.2 lx
(2%): 0.4 lx
(5%): 1.0 lx
(10%): 2.0 lx
(20%): 4.0 lx
(50%): 10.0 lx
(100%): 19.9 lx

C Plane (°):0.0-180.0: 180.0
Gamma Plane (°):0.0-90.0:1.0
Test Lab:
Test Device: CHL-6E
Test Type: TYPE C
Distance: 3.010 m
Temperature:
Humidity:
Operator:
Inspector:

Illuminance at a Distance




Dist(m)	Enadir(lx)	Dh/Dv_B(m)	S_B(sq.m)	Eav_B(lx)
0.5	7959.20	0.46/0.46	0.2	3400.45
1.0	1989.80	0.91/0.92	0.7	850.11
1.5	884.36	1.37/1.37	1.5	377.83
2.0	497.45	1.83/1.83	2.6	212.53
2.5	318.37	2.28/2.29	4.1	136.02
3.0	221.09	2.74/2.75	5.9	94.46
4.0	124.36	3.65/3.66	10.5	53.13
5.0	79.59	4.57/4.58	16.4	34.00
15.0	8.84	13.70/13.73	147.8	3.78
20.0	4.97	18.27/18.31	262.8	2.13

Beam Angle(B): H49.1 V49.2 Field Angle(F): H71.6 V71.6

C Plane (°):0.0-180.0: 180.0
Test Lab:
Test Type: TYPE C
Temperature:
Operator:

Gamma Plane (°):0.0-90.0:1.0
Test Device: CHL-6E
Distance: 3.010 m
Humidity:
Inspector:

Vertical IsoLux Plot



Lowest(m): 1.0m Highest(m): 11.0m Max Lux: 1989.8 lx

(1%): 19.9 lx
(2%): 39.8 lx
(5%): 99.5 lx
(10%): 199.0 lx
(20%): 398.0 lx
(50%): 994.9 lx
(100%):1989.8 lx

C Plane (°):0.0-180.0: 180.0
Gamma Plane (°):0.0-90.0:1.0
Test Lab:
Test Device: CHL-6E
Test Type: TYPE C
Distance: 3.010 m
Temperature:
Humidity:
Operator:
Inspector:

Area Flux Table


Unit: lm

Horizontal plane	Vertical plane																									
	-90	-80	-70	-60	-50	-40	-30	-20	-10	0	10	20	30	40	50	60	70	80	90	Flux(T)	Flux(E)
-90	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
-80	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0
-70	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.5	0.0
-60	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.2	0.2	0.2	0.2	0.1	0.1	0.0	0.0	0.0	0.0	0.0	1.8	0.0
-50	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.2	0.3	0.5	0.7	1.0	1.0	0.7	0.5	0.3	0.2	0.1	0.0	5.6	0.0
-40	0.0	0.0	0.0	0.0	0.1	0.2	0.4	0.7	1.9	4.0	6.2	6.2	4.0	1.9	0.7	0.4	0.2	0.1	0.0	26.9	13.3
-30	0.0	0.0	0.0	0.1	0.3	0.6	2.1	7.4	17.6	25.0	25.0	17.6	7.4	2.1	0.6	0.3	0.1	0.1	0.0	106.0	96.8
-20	0.0	0.0	0.0	0.1	0.4	1.0	4.7	18.6	36.6	46.8	46.8	36.6	18.6	4.7	1.0	0.4	0.1	0.1	0.0	216.7	208.4
-10	0.0	0.0	0.0	0.2	0.5	1.4	7.4	27.5	48.4	58.4	58.4	48.4	27.5	7.4	1.4	0.5	0.2	0.1	0.0	287.5	279.6
0	0.0	0.0	0.0	0.2	0.5	1.4	7.4	27.5	48.6	58.7	58.7	48.6	27.5	7.4	1.4	0.5	0.2	0.1	0.0	288.6	280.8
10	0.0	0.0	0.0	0.1	0.4	1.1	4.7	18.7	36.9	47.4	47.4	36.9	18.7	4.7	1.1	0.4	0.2	0.1	0.0	218.7	210.2
20	0.0	0.0	0.0	0.1	0.3	0.7	2.1	7.3	17.6	25.3	25.3	17.6	7.3	2.1	0.7	0.3	0.1	0.1	0.0	107.1	97.5
30	0.0	0.0	0.0	0.1	0.2	0.4	0.8	2.0	4.1	6.2	6.2	4.1	2.0	0.8	0.4	0.2	0.1	0.0	0.0	27.5	13.2
40	0.0	0.0	0.0	0.0	0.1	0.2	0.4	0.5	0.8	1.1	1.1	0.8	0.5	0.4	0.2	0.1	0.0	0.0	0.0	6.5	0.0
50	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.2	0.3	0.3	0.3	0.3	0.2	0.1	0.1	0.0	0.0	0.0	0.0	2.1	0.0
60	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.1	0.1	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.6	0.0
70	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0
80	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
90	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1296	Flux(T)
Flux(E)	1200	0.0	0.0	0.0	0.0	0.0	15.4	104.0	209.5	271.0	271.0	216.0	112.4	31.1	7.6	3.0	1.1	0.3	0.0	0.0	Flux(E)

C Plane (°):0.0-180.0: 180.0
Test Lab:
Test Type: TYPE C
Temperature:
Operator:

Gamma Plane (°):0.0-90.0:1.0
Test Device: CHL-6E
Distance: 3.010 m
Humidity:
Inspector:

The Average Illuminance Effective Figure



C Plane (°):0.0-180.0: 180.0
Test Lab:
Test Type: TYPE C
Temperature:
Operator:

Gamma Plane (°):0.0-90.0:1.0
Test Device: CHL-6E
Distance: 3.010 m
Humidity:
Inspector:

UGR Table


Reflectance: Ceiling (cavity)	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions	Viewed crosswise					Viewed endwise				
X=2H Y=2H	19.2	20.0	19.5	20.2	20.4	19.2	20.0	19.4	20.2	20.4
3H	19.1	19.8	19.4	20.1	20.3	19.1	19.8	19.4	20.0	20.3
4H	19.1	19.7	19.4	20.0	20.3	19.0	19.7	19.3	19.9	20.2
6H	19.0	19.6	19.3	19.9	20.2	18.9	19.6	19.3	19.8	20.1
8H	19.0	19.6	19.3	19.9	20.2	18.9	19.5	19.2	19.8	20.1
12H	18.9	19.5	19.3	19.8	20.1	18.9	19.4	19.2	19.7	20.1
X=4H Y=2H	19.1	19.7	19.4	20.0	20.3	19.0	19.7	19.3	19.9	20.2
3H	19.0	19.5	19.3	19.9	20.2	18.9	19.5	19.3	19.8	20.1
4H	18.9	19.4	19.3	19.8	20.1	18.8	19.4	19.2	19.7	20.0
6H	18.8	19.3	19.3	19.7	20.0	18.8	19.2	19.2	19.6	20.0
8H	18.8	19.2	19.2	19.6	20.0	18.7	19.1	19.2	19.5	19.9
12H	18.8	19.1	19.2	19.5	20.0	18.7	19.0	19.1	19.5	19.9
X=8H Y=4H	18.8	19.2	19.2	19.6	20.0	18.7	19.1	19.2	19.5	19.9
6H	18.7	19.0	19.2	19.5	19.9	18.6	19.0	19.1	19.4	19.9
8H	18.7	19.0	19.2	19.4	19.9	18.6	18.9	19.1	19.3	19.8
12H	18.6	18.9	19.1	19.4	19.8	18.6	18.8	19.0	19.3	19.8
X=12H Y=4H	18.8	19.1	19.2	19.5	20.0	18.7	19.1	19.1	19.5	19.9
6H	18.7	19.0	19.1	19.4	19.9	18.6	18.9	19.1	19.3	19.8
8H	18.6	18.9	19.1	19.4	19.8	18.6	18.8	19.0	19.3	19.8
Variations with the observer position at spacings:										
S=1.0H	+5.2/-6.4					+5.3/-6.8				
S=1.5H	+7.9/-8.6					+8.0/-9.0				
S=2.0H	+9.9/-10.4					+10.0/-11.0				

Calculate in accordance with CIE Pub.117. The table is revised with 1297lm (8log(F/F0) = 0.9).

C Plane (°):0.0-180.0: 180.0
Test Lab:
Test Type: TYPE C
Temperature:
Operator:

Gamma Plane (°):0.0-90.0:1.0
Test Device: CHL-6E
Distance: 3.010 m
Humidity:
Inspector:

FLUX DISTRIBUTION TABLE BASED ON THE IESNA LUMINAIRE CLASSIFICATION SYSTEM



ZONE	LUMENS	% LAMP LUMENS
FORWARD LIGHT	651	50.2
FL (0°-30°)	542	41.8
FM (30°-60°)	106	8.2
FH (60°-80°)	3	0.3
FVH (80°-90°)	0	0.0
BACK LIGHT	645	49.8
BL (0°-30°)	538	41.5
BM (30°-60°)	104	8.0
BH (60°-80°)	3	0.2
BVH (80°-90°)	0	0.0
UP LIGHT	0	0.0
UL (90°-100°)	0	0.0
UH (100°-180°)	0	0.0
TRAPPED LIGHT	NA	NA

BUG(**B**acklight,**U**plight,**G**lare) Rating Base On TM-15-07	
Asymmetrical Luminaire Types (Type I,II,III,IV)	B2 U0 G0
Quadrilateral Symmetrical Luminaire Types (Type V,Area Light)	B2 U0 G0

C Plane (°):0.0-180.0: 180.0
Test Lab:
Test Type: TYPE C
Temperature:
Operator:

Gamma Plane (°):0.0-90.0:1.0
Test Device: CHL-6E
Distance: 3.010 m
Humidity:
Inspector:

Zonal Lumen

Gamma [°]	Imean [cd]	Zonal Flux [lm]	Sum Zonal Flux [lm]	Rel Zonal Flux [%]	Sum Rel Zonal Flux [%]
0.0-1.0	1989.7	1.9	1.9	0.15	0.15
1.0-2.0	1989.7	5.7	7.6	0.44	0.59
2.0-3.0	1989.0	9.5	17.1	0.73	1.32
3.0-4.0	1986.7	13.3	30.4	1.03	2.35
4.0-5.0	1982.2	17.1	47.5	1.32	3.66
5.0-6.0	1975.2	20.8	68.2	1.60	5.26
6.0-7.0	1965.6	24.4	92.6	1.88	7.14
7.0-8.0	1952.0	27.9	120.6	2.15	9.30
8.0-9.0	1933.9	31.3	151.9	2.42	11.72
9.0-10.0	1910.3	34.6	186.5	2.67	14.38
10.0-11.0	1880.1	37.6	224.1	2.90	17.28
11.0-12.0	1843.7	40.3	264.4	3.11	20.39
12.0-13.0	1800.8	42.7	307.1	3.30	23.69
13.0-14.0	1753.5	44.9	352.0	3.46	27.15
14.0-15.0	1703.6	46.8	398.8	3.61	30.76
15.0-16.0	1649.1	48.3	447.1	3.73	34.48
16.0-17.0	1590.2	49.5	496.6	3.82	38.30
17.0-18.0	1527.9	50.4	547.0	3.89	42.19
18.0-19.0	1461.4	50.9	597.9	3.92	46.11
19.0-20.0	1390.7	50.9	648.8	3.93	50.04
20.0-21.0	1316.7	50.6	699.4	3.90	53.93
21.0-22.0	1241.2	49.9	749.2	3.85	57.78
22.0-23.0	1164.5	48.9	798.1	3.77	61.55
23.0-24.0	1084.8	47.4	845.5	3.66	65.21
24.0-25.0	1002.7	45.6	891.1	3.52	68.73
25.0-26.0	920.1	43.4	934.6	3.35	72.08
26.0-27.0	837.4	41.0	975.6	3.16	75.24
27.0-28.0	753.4	38.2	1013.7	2.94	78.18
28.0-29.0	668.6	35.0	1048.7	2.70	80.88
29.0-30.0	585.3	31.6	1080.3	2.44	83.31
30.0-31.0	506.2	28.2	1108.5	2.17	85.49
31.0-32.0	432.6	24.8	1133.3	1.91	87.40
32.0-33.0	365.3	21.5	1154.8	1.66	89.06
33.0-34.0	305.6	18.5	1173.3	1.43	90.48
34.0-35.0	254.3	15.8	1189.1	1.22	91.70
35.0-36.0	210.8	13.4	1202.5	1.04	92.74

C Plane (°):0.0-180.0: 180.0
Test Lab:
Test Type: TYPE C
Temperature:
Operator:

Gamma Plane (°):0.0-90.0:1.0
Test Device: CHL-6E
Distance: 3.010 m
Humidity:
Inspector:

Zonal Lumen (Continue 1)

Gamma [°]	Imean [cd]	Zonal Flux [lm]	Sum Zonal Flux [lm]	Rel Zonal Flux [%]	Sum Rel Zonal Flux [%]
36.0-37.0	175.0	11.4	1213.9	0.88	93.62
37.0-38.0	146.2	9.8	1223.7	0.75	94.37
38.0-39.0	123.4	8.4	1232.1	0.65	95.02
39.0-40.0	105.2	7.3	1239.4	0.57	95.59
40.0-41.0	90.2	6.4	1245.9	0.50	96.08
41.0-42.0	77.1	5.6	1251.5	0.43	96.51
42.0-43.0	65.9	4.9	1256.4	0.38	96.89
43.0-44.0	56.4	4.3	1260.6	0.33	97.22
44.0-45.0	47.7	3.7	1264.3	0.28	97.50
45.0-46.0	39.4	3.1	1267.4	0.24	97.74
46.0-47.0	32.4	2.6	1269.9	0.20	97.94
47.0-48.0	27.8	2.3	1272.2	0.17	98.11
48.0-49.0	25.4	2.1	1274.3	0.16	98.27
49.0-50.0	23.6	2.0	1276.2	0.15	98.42
50.0-51.0	21.9	1.9	1278.1	0.14	98.57
51.0-52.0	20.4	1.7	1279.8	0.13	98.70
52.0-53.0	19.0	1.7	1281.5	0.13	98.83
53.0-54.0	17.7	1.6	1283.1	0.12	98.95
54.0-55.0	16.3	1.5	1284.5	0.11	99.06
55.0-56.0	14.8	1.3	1285.9	0.10	99.17
56.0-57.0	13.3	1.2	1287.1	0.09	99.26
57.0-58.0	11.9	1.1	1288.2	0.08	99.34
58.0-59.0	10.6	1.0	1289.2	0.08	99.42
59.0-60.0	9.4	0.9	1290.0	0.07	99.49
60.0-61.0	8.3	0.8	1290.8	0.06	99.55
61.0-62.0	7.5	0.7	1291.6	0.06	99.61
62.0-63.0	6.6	0.6	1292.2	0.05	99.66
63.0-64.0	5.8	0.6	1292.8	0.04	99.70
64.0-65.0	5.1	0.5	1293.3	0.04	99.74
65.0-66.0	4.5	0.4	1293.7	0.03	99.77
66.0-67.0	4.0	0.4	1294.1	0.03	99.80
67.0-68.0	3.6	0.4	1294.5	0.03	99.83
68.0-69.0	3.1	0.3	1294.8	0.02	99.86
69.0-70.0	2.8	0.3	1295.1	0.02	99.88
70.0-71.0	2.5	0.3	1295.3	0.02	99.90
71.0-72.0	2.1	0.2	1295.6	0.02	99.92

C Plane (°):0.0-180.0: 180.0
Test Lab:
Test Type: TYPE C
Temperature:
Operator:

Gamma Plane (°):0.0-90.0:1.0
Test Device: CHL-6E
Distance: 3.010 m
Humidity:
Inspector:

Zonal Lumen (Continue 2)

Gamma [°]	Imean [cd]	Zonal Flux [lm]	Sum Zonal Flux [lm]	Rel Zonal Flux [%]	Sum Rel Zonal Flux [%]
72.0-73.0	1.8	0.2	1295.8	0.01	99.93
73.0-74.0	1.6	0.2	1295.9	0.01	99.94
74.0-75.0	1.5	0.2	1296.1	0.01	99.95
75.0-76.0	1.3	0.1	1296.2	0.01	99.96
76.0-77.0	1.1	0.1	1296.3	0.01	99.97
77.0-78.0	0.8	0.1	1296.4	0.01	99.98
78.0-79.0	0.6	0.1	1296.5	0.00	99.99
79.0-80.0	0.6	0.1	1296.5	0.00	99.99
80.0-81.0	0.5	0.0	1296.6	0.00	99.99
81.0-82.0	0.3	0.0	1296.6	0.00	100.00
82.0-83.0	0.2	0.0	1296.6	0.00	100.00
83.0-84.0	0.1	0.0	1296.7	0.00	100.00
84.0-85.0	0.1	0.0	1296.7	0.00	100.00
85.0-86.0	0.0	0.0	1296.7	0.00	100.00
86.0-87.0	0.0	0.0	1296.7	0.00	100.00
87.0-88.0	0.0	0.0	1296.7	0.00	100.00
88.0-89.0	0.0	0.0	1296.7	0.00	100.00
89.0-90.0	0.0	0.0	1296.7	0.00	100.00

C Plane (°):0.0-180.0: 180.0
Test Lab:
Test Type: TYPE C
Temperature:
Operator:

Gamma Plane (°):0.0-90.0:1.0
Test Device: CHL-6E
Distance: 3.010 m
Humidity:
Inspector:

Candlepower Table

Unit: cd

G\C	C0.0	C180.0								
G0.0	1989.8	1989.8								
G1.0	1992.8	1986.3								
G2.0	1996.4	1983.3								
G3.0	1996.7	1979.4								
G4.0	1996.1	1974.5								
G5.0	1990.7	1967.4								
G6.0	1983.5	1959.2								
G7.0	1973.0	1946.7								
G8.0	1957.8	1930.3								
G9.0	1937.4	1909.9								
G10.0	1909.9	1884.1								
G11.0	1874.3	1852.1								
G12.0	1835.5	1812.8								
G13.0	1789.7	1765.2								
G14.0	1740.6	1718.5								
G15.0	1688.6	1666.6								
G16.0	1632.3	1608.8								
G17.0	1573.0	1546.9								
G18.0	1508.8	1483.1								
G19.0	1438.8	1415.1								
G20.0	1366.3	1342.7								
G21.0	1290.9	1266.9								
G22.0	1214.2	1192.9								
G23.0	1134.6	1116.4								
G24.0	1052.2	1036.1								
G25.0	969.3	953.1								
G26.0	885.8	872.3								
G27.0	801.0	790.6								
G28.0	714.7	707.5								
G29.0	627.3	625.0								
G30.0	543.2	545.8								
G31.0	465.7	469.9								
G32.0	395.6	399.2								
G33.0	331.4	334.8								
G34.0	277.2	279.3								
G35.0	229.7	231.2								
G36.0	191.0	191.1								

C Plane (°):0.0-180.0: 180.0
Test Lab:
Test Type: TYPE C
Temperature:
Operator:

Gamma Plane (°):0.0-90.0:1.0
Test Device: CHL-6E
Distance: 3.010 m
Humidity:
Inspector:

Candlepower Table (Continue 1)

Unit: cd

G\C	C0.0	C180.0								
G37.0	160.1	157.9								
G38.0	135.6	131.4								
G39.0	115.6	110.9								
G40.0	100.1	94.1								
G41.0	87.1	79.4								
G42.0	75.4	66.7								
G43.0	65.2	56.5								
G44.0	56.5	47.6								
G45.0	48.2	38.6								
G46.0	39.8	31.1								
G47.0	32.4	26.4								
G48.0	28.2	24.3								
G49.0	26.3	22.7								
G50.0	24.5	20.9								
G51.0	22.8	19.4								
G52.0	21.2	18.2								
G53.0	20.0	16.8								
G54.0	18.6	15.5								
G55.0	17.1	14.0								
G56.0	15.6	12.5								
G57.0	14.1	11.0								
G58.0	12.6	9.8								
G59.0	11.1	8.9								
G60.0	9.9	7.7								
G61.0	8.9	6.9								
G62.0	8.0	6.2								
G63.0	6.9	5.4								
G64.0	6.0	4.8								
G65.0	5.4	4.2								
G66.0	4.8	3.6								
G67.0	4.3	3.2								
G68.0	3.9	2.8								
G69.0	3.5	2.4								
G70.0	3.0	2.3								
G71.0	2.7	2.0								
G72.0	2.3	1.6								
G73.0	2.0	1.4								

C Plane (°):0.0-180.0: 180.0
Test Lab:
Test Type: TYPE C
Temperature:
Operator:

Gamma Plane (°):0.0-90.0:1.0
Test Device: CHL-6E
Distance: 3.010 m
Humidity:
Inspector:

Candlepower Table (Continue 2)

Unit: cd

G\C	C0.0	C180.0								
G74.0	1.8	1.2								
G75.0	1.8	1.0								
G76.0	1.2	1.0								
G77.0	1.2	0.8								
G78.0	0.9	0.4								
G79.0	0.6	0.4								
G80.0	0.8	0.4								
G81.0	0.4	0.2								
G82.0	0.4	0.2								
G83.0	0.2	0.2								
G84.0	0.2	0.0								
G85.0	0.2	0.0								
G86.0	0.0	0.0								
G87.0	0.0	0.0								
G88.0	0.0	0.0								
G89.0	0.0	0.0								
G90.0	0.0	0.0								

C Plane (°):0.0-180.0: 180.0
Test Lab:
Test Type: TYPE C
Temperature:
Operator:

Gamma Plane (°):0.0-90.0:1.0
Test Device: CHL-6E
Distance: 3.010 m
Humidity:
Inspector: